

Release notes

Release Notes:
iCube Web HMI App

Release note
Document type

DMC
Division

27.02.2026
Date

Version Information:

iCube Web HMI App: 1.4.1

Fixes included in this release

ID	Title	Description
82249	Unexpected controller restart triggered by Web HMI App project transfers	<p>Potentially Critical Runtime Behavior When Using the Web HMI App on iCube Controllers</p> <p>When the Web HMI app is used on an iCube Controller, it may prevent other monitoring functions of the controller from correctly triggering the system watchdog. As a result, the machine or plant controlled by the iCube Controller may enter uncontrolled and potentially critical operating states.</p> <p>The Web HMI app triggers the system watchdog, which leads to a system restart if the visualization project is transferred to the Web HMI app repeatedly (at least five times). This may result in the loss of any retain data stored in the iCube Controller.</p>